

Fire Marshal Survey

AHJ Information

Jurisdiction Name Miami Valley Fire District AHJ Name Lt Dale Fahrney, Fire Marshal
 Department Name Fire Prevention Phone Number 937-560-2115
 AHJ Address 2710 Lyons Road City Miamisburg State Ohio
 Website <http://www.miamitownshipfire-ems.com> E-Mail dale.fahrney@miamivalleyfiredistrict.org Zip 45342
 Comments _____

Code Information

What Code and Version do you use?

NFPA: 2010
 Ohio Building Code: 2011
 Other: 2011 Ohio Fire Code

Are there any amendments to the code that would effect the Fire Alarm System? _____

Requirements

Is combination Panel Acceptable Yes Separate Panel Addressable Required

Wiring Requirements
 Initiating Class A Class B Indicating Class A Class B

Conduit Requirements
 Full Conduit Below 10 feet (NEC)

Smoke Detector Requirements
 None At Panel Full Smoke Selected areas

Exception for Elimination of Pulls in Fully Sprinkled Buildings Allowed Not Allowed, All Exits

Single Pull Station Location Requirement Constantly Attended Location At Panel Front Door

Annunciator Type Required
 None LCD LED Graphic Special Requirements

Annunciator / Keypad Location
 Front Door / Main Entrance Attended Location Sprinkler riser Special Requirements

Are Graphic Zone Maps Required Yes No Size 8.5 x 11.0 Location Annunciator Panel

Are Fire Alarm Inspections Required Yes No Frequency Annually Bi-Annually Quarterly

Requirements for Outside PIVs
 Monitored by Fire System Can be chained and locked Other, see Comments

Duct Detectors

Monitoring of Duct Detectors None Supervisory Alarm

Mounting Location Supply only Return only Supply and Return

Remote Test Switches None Below HVAC Unit At Fire Panel On Wall near Unit(s)

Duct Detectors Powered By HVAC Unit By Fire Panel

HVAC Shutdown Control None Unit Only All Units Ducts only All Units Any Alarm

Recall

Elevator Recall None Passenger Only Freight only All Elevators

If not capable of recall, what are the options None, Must have Recall Options, see Comments Below

Notification

Notification Required None Full Notification One Inside

Horn Strobes or Voice Evacuatio Horn Strobes Voice Evacuation

Can Horn Strobes Be Ceiling Mounted No Ceiling Mount is OK

Horn Strobe Required Outside None Sprinkler Connection Front of Bldg.

Mounting Height of Outside Horn/Strobe
 Height _____ Other Location _____

Fire Marshal Survey

AHJ Information

Jurisdiction Name Miami Valley Fire District AHJ Name Lt Dale Fahrney, Fire Marshal
 Department Name Fire Prevention Phone Number 937-560-2115
 AHJ Address 2710 Lyons Road City Miamisburg State Ohio
 Website <http://www.miamitownshipfire-ems.com> E-Mail dale.fahrney@miamivalleyfiredistrict.org Zip 45342
 Comments _____

Code Information

What Code and Version do you use?

NFPA: 2010
 Ohio Building Code: 2011
 Other: 2011 Ohio Fire Code

Are there any amendments to the code that would effect the Fire Alarm System?

Monitoring

Dedicated Phone Lines Required
 Type of Monitoring
 Other Requirements
 Is a Mall Tie-In Required
 Signals to be sent to mall system
 Monitoring Location

Primary Line Only Secondary Line Only Both Lines

Remote Station Central Station Direct Connect

Master Box Radio UL Certificate Required

Yes No Location of Mall System

Alarm Trouble Supervisory Waterflow

Remote Station Monitoring Other Specify _____

Permitting

Is a Fire Alarm Permit required
 Other Costs (Plans Review, Bldg, Electrical)
 Can Work Begin Before Permit Is Issued
 Is Knox Box Required
 Height of Knox Box

No Yes Cost _____

No Yes

No Yes Order from Fire Dept and Locate per Fire Dept Instructions.

Height Knox Box Number Required

Submittal

Submittals Required
 3rd Party Contact Information
 Num Of Sets / Scale / Turn around time
 Paper Size
 Stamp Required
 At what point are Resubmittals required

No Yes 3rd Party / Engineer Review

1/8 Scale 1/16 Scale Other-Specify below **2** Days Weeks

30 x 42 24 x 36 Other - Please specify

No Engineers California C-10 NICET

Any Changes to the approved plans will require as built drawings.

Comments

